



KEY NOTES

- 01 Brick veneer
- 02 Concrete masonry w/ grout & reinforcement as req'd
- 14 Precast concrete U-lintel, grouted
- 31 Horizontal joint reinforcement
- 32 Veneer anchor
- 36 Drainage cavity
- 41 Insulation
- 51 Thru-wall flashing (end dams not shown)
- 52 Termination bar w/ cont. bead of sealant @ top
- 54 Drip Edge
- 59 Weep vent
- 61 Air/moisture/vapor barrier as req'd
- 72 Masonry expansion joint as req'd
- 81 Window assembly
- 91 Steel lintel angle

KEY WORDS

Anchored veneer, CMU, Cavity wall, Head, Lintel, End dam, Flashing, masonry lintel, bond beam, 01.030.0605

International Masonry Institute

team MASONRY
DETAILING
SERIES

800-IMI-0988

www.imiweb.org

Note: Code requirements for non-combustible construction types may affect insulation, water-resistive barrier, and other materials used within the window head assembly.

Window Head | Brick veneer, CMU backup, precast concrete lintel
Detail 01.030.0605 Rev. 10/13/17