

MASONRY COPING: LIMESTONE, CAST STONE, CALCIUM SILICATE, OR PRECAST CONCRETE; OVERHANG MASONRY WALL 1½+MIN.; SLOPED TOP

1/8" SAW-CUT DRIP, BOTH SIDES OF WALL CAP

SEALANT & BACKER ROD, BOTH SIDES OF WALL CAP

FACE BRICK

SLOPED MORTAR BED TO SUPPORT CANTED FLASHING, OPT.

RIGID INSULATION

OPEN DRAINAGE CAVITY, OPTIONAL ABOVE ROOF LINE; ALSO SEE DETAIL 01.752

S.S. DOWEL W/ SEALANT AROUND PENETRATIONS THROUGH FLASHING

SEE DETAIL 01.759 FOR WALL CAP JOINT OPTIONS

CANTED S.S. THRU-WALL FLASHING W/ 1/2" EXPOSED DRIP EDGE

SEALANT BELOW DRIP, OPT. (NOT SHOWN)

GROUT & REINFORCING AS REQ'D.

HORIZONTAL JOINT REINFORCEMENT W/ WALL TIES

MASONRY WALL CAP OPEN CAVITY

DETAIL 01.030.0801

REV. 011/04/08

International Masonry Institute



800-IMI-0988 www.imiweb.org

© 2011 INTERNATIONAL MASONRY INSTITUTE