



NOTE:  
STRUCTURAL ELEMENTS  
MAY VARY, AND ARE SHOWN  
FOR ILLUSTRATION ONLY

CAVITY INSULATION NOT  
SHOWN FOR CLARITY OF  
DETAIL

CARRY FLASHING 1/2" MIN.  
BEYOND END OF LINTEL

PREFABRICATED END DAM  
IN HEAD JOINT; SET IN  
MASTIC IF FLASHING IS NOT  
SELF-ADHERING. END DAM  
PLACED PRIOR TO  
THROUGH-WALL FLASHING

2" RECOMMENDED;  
1" MIN.

SEALANT

EXTEND FLASHING  
FLUSH OR BEYOND  
FACE OF MASONRY

**END DAM DIAGRAM**    PREFABRICATED FLASHING END DAM

DIAGRAM 01.410.0202

REV. 02/04/11

International Masonry Institute



800-IMI-0988    www.imiweb.org

© 2011 INTERNATIONAL MASONRY INSTITUTE