



PRECAST CONCRETE PLANK

SOLID CMU

BOND BEAM W/ (2) #5, CONT., OR AS REQ'D

HORIZ. JOINT REINFORCEMENT

NOTE: VENEER & AIR/MOISTURE BARRIER NOT SHOWN

GROUT & VERTICAL REINFORCING AS REQ'D.

2'-0 HORIZ. x 2'-0" VERT. #4 DOWELS AND GROUT AT PLANK KEYWAYS

3" MIN. BEARING & BEARING STRIP

PLANK AT BEARING WALL TOP OF WALL
 DETAIL 02.120.0851 REV. 11/25/08