

KEY NOTES $\langle 01 \rangle$ Brick veneer $\langle 02 \rangle$ Concrete masonry backup $\langle 05 \rangle$ Slab on grade $\langle 22 \rangle$ Grout per structural design $\langle 31 \rangle$ Horizontal joint reinf. w/ eye & pintle veneer anchors $\langle 32 \rangle$ Veneer anchor $\langle 34 \rangle$ Cavity drainage insert $\langle 36 \rangle$ Air space: 2" recommended, 1" min. req'd by code $\langle 37 \rangle$ Reinforcement per structural design $\langle 41 \rangle$ Insulation $\langle 51 \rangle$ Thru-wall flashing $\langle 52 \rangle$ Termination bar w/ cont. bead of sealant @ top $\langle 54 \rangle$ Drip edge: seal and adhere to foundation $\left< 59 \right>$ Weep vents Air/moisture/vapor 61 barrier as req'd $\langle 63 \rangle$ Below grade waterproofing compatible w/ substrate

