

## **KEY NOTES**

- (01) Brick veneer
- O2 Concrete masonry backup
- (10) Wood blocking
- 22 Grout per structural design
- Horizontal joint reinf. w/ eye & pintle veneer anchors
- (32) Veneer anchor
- (34) Cavity drainage insert
- Air space: 2" recommended, 1" min. req'd by code
- Reinforcement per structural design
- 41 Insulation
- (51) Thru-wall flashing
- 52 Termination bar w/ cont. bead of sealant @ top
- (53) Flashing end dam
- 54 Drip edge
- 59 Weep vents
- Air/moisture/vapor barrier as reg'd
- (64) Transition membrane
- 8 Brick expansion joint: sealant, backer rod, and compressible filler
- (73) Control joint
- (74) Sealant & backer rod around window

International Masonry Institute



800-IMI-0988

www.imiweb.org