



KEY NOTES

- 01 Brick veneer
- 02 Concrete masonry w/ grout & reinforcement as req'd
- 05 Concrete masonry course notched around double angle lintel
- 31 Horizontal joint reinforcement
- 32 Veneer anchor
- 36 Air space
- 41 Insulation
- 51 Thru-wall flashing (end dams not shown)
- 52 Termination bar w/ cont. bead of sealant @ top
- 54 Drip Edge
- 59 Weep vent
- 61 Air/moisture/vapor barrier as req'd
- 72 Masonry expansion joint as req'd
- 81 Window assembly
- 91 Loose steel lintel

KEY WORDS

Anchored veneer, CMU, Cavity wall, Head, Lintel, End dam, Flashing, 01.030.0603, Steel, Angle

Note: Code requirements for non-combustible construction types may affect insulation, water-resistive barrier, and other materials used within the window head assembly.

Window Head | Brick veneer, CMU backup, double angle lintel
 Detail 01.030.0603 Rev. 11/09/17

