



KEY NOTES

- 01 Brick veneer
- 02 Concrete masonry w/ grout & reinforcement as req'd
- 05 Concrete masonry soap cut to fit around beam
- 31 Horizontal joint reinforcement
- 32 Veneer anchor
- 33 Welded stud
- 36 Air space
- 41 Insulation
- 51 Thru-wall flashing (end dams not shown)
- 52 Termination bar w/ cont. bead of sealant @ top
- 54 Drip edge
- 59 Weep vent
- 61 Air/moisture/vapor barrier as req'd
- 72 Masonry expansion joint as req'd
- 81 Window assembly
- 91 Structural steel lintel: steel beam welded to steel plate

KEY WORDS

Anchored veneer, CMU, Cavity wall, Head, Lintel, End dam, Flashing, Expansion joint, Movement joint, 01.030.0604, Plate, Beam, Steel

International Masonry Institute



800-IMI-0988

www.imiweb.org

Note: Code requirements for non-combustible construction types may affect insulation, water-resistive barrier, and other materials used within the window head assembly.

Window Head | Brick veneer, CMU backup, structural steel beam/plate lintel

Detail 01.030.0604

Rev. 11/09/17