

KEY NOTES

01 Brick veneer

22

(02)

(05)

- Concrete masonry backup
- (05) Floor slab, connection detail may vary
- (22) Grout per structural design
- (31) Horizontal joint reinf. w/ eye & pintle veneer anchors
- (32) Veneer anchor
- 36 Air space: 2" recommended, 1" min. req'd by code
- $\langle \overline{37} \rangle$ Reinforcement per structural design
- 41 Insulation
- 51 Thru-wall flashing
- $\langle 52 \rangle$ Termination bar w/ cont. bead of sealant @ top
- (54) Drip edge, adhesive sealant not shown
- ⟨59⟩ Weep vents
- (60) Vents at top of air space, optional
- Air/moisture/vapor barrier as reg'd
- $\langle 72 \rangle$ Horizontal expansion joint: sealant, backer rod, and compressible

KEY WORDS

Shelf angle, Floor slab, Veneer, Brick, Flashing, Drainage, Weeps, High-performing, 01.030.0704, Thermal bridge, Standoff, Standoff brackets, Anchored veneer



Detail 01.030.0704

Rev. 09/04/18