



TERMINATE HORIZONTAL  
JOINT REINFORCEMENT AT  
CONTROL JOINT

GROUT & REINFORCING  
WHERE REQUIRED

CERAMIC FIBER BLANKET  
WHERE REQUIRED FOR  
FIRE RATING

CAULK & BACKER ROD

NOTE: STRUCTURAL ELEMENTS  
MAY VARY, AND ARE SHOWN FOR  
ILLUSTRATION ONLY

# CONTROL JOINT FIRE-RATED

DETAIL 02.010.1303

REV. 03/14/11

International Masonry Institute



800-IMI-0988 www.imiweb.org

© 2011 INTERNATIONAL MASONRY INSTITUTE